

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Spartan Controls Ltd.	Manufacturer:	Spartan Controls Ltd.
Address:	#60, 11550 Barlow Trail NE Calgary, AB, T3N 1A7	Address:	#60, 11550 Barlow Trail NE Calgary, AB, T3N 1A7
Country:	Canada	Country:	Canada
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Intertek Testing Services (ITS) Ltd, Edmonton, Alberta		
Control Number:	<u>5019382</u>	Authorized by:	<u><i>L. Matthew Snyder</i></u> for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Industrial Control Panels [UL 508A:2018 Ed.3+R:28Jul2022] Industrial Control Panels and Assemblies [CSA C22.2#286:2023 Ed. 3]
Product:	Industrial Control Panels For General Use, Industrial Control Panels for Motor Control, Industrial Control Panels for process control equipment, Industrial Control Panels For Control Of Gas- and/or Oil-Burning Equipment, Industrial Control Panels For Flame Control, Industrial Control Panels For Air Conditioning And Refrigeration Equipment
Models:	Custom Industrial Control Panels

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Spartan Controls Ltd.	Manufacturer:	Spartan Controls Ltd.
Address:	#60, 11550 Barlow Trail NE Calgary, AB, T3N 1A7	Address:	#60, 11550 Barlow Trail NE Calgary, AB, T3N 1A7
Country:	Canada	Country:	Canada
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Intertek Testing Services (ITS) Ltd, Edmonton, Alberta		
Control Number:	<u>5019382</u>	Authorized by:	<u><i>L. Matthew Snyder</i></u> for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations [UL 121201:2017 Ed.9+R:01Apr2021] Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations [CSA C22.2#213:2017 Ed.3+U1;U2;U3]
Product:	Industrial Control Panels for use in or having non-incendive field wiring to Class I and II, Division 2, and Class III, Division 1 and 2 Hazardous (Classified) Locations
Models:	Custom Industrial Control Panels

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Spartan Controls Ltd
Address: #60, 11550 Barlow Trail NE
 Calgary, AB, T3N 1A7
Country: Canada

Manufacturer: Spartan Controls Ltd
Address: #60, 11550 Barlow Trail NE
 Calgary, AB, T3N 1A7
Country: Canada

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Intertek Testing Services (ITS) Ltd, Edmonton, Alberta

Control Number: 5019382 **Authorized by:** *Miller Habe*
 for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
 545 East Algonquin Road, Arlington Heights, IL 60005
 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Industrial Control Panels Relating To Hazardous (Classified) Locations [UL 698A:2018 Ed.4+R:17Jan2019]
	Industrial Control Panels and Assemblies [CSA C22.2#286:2023 Ed.3]
Product:	Industrial Control Panels Relating To Hazardous (Classified) Locations
Models:	Custom Industrial Control Panels

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Spartan Controls Ltd.	Manufacturer:	Spartan Controls Ltd.
Address:	#60, 11550 Barlow Trail NE Calgary, AB, T3N 1A7	Address:	#60, 11550 Barlow Trail NE Calgary, AB, T3N 1A7
Country:	Canada	Country:	Canada
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Intertek Testing Services (ITS) Ltd, Edmonton, Alberta		
Control Number:	<u>5019382</u>	Authorized by:	<u><i>Matthew Snyder</i></u> for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations [UL 1203:2013 Ed.5+R:05Apr2022] Explosion-proof Equipment [CSA C22.2#30:2020 Ed.4] Industrial Control Panels [UL 508A:2018 Ed.3+R:28Jul2022] Industrial Control Panels and Assemblies [CSA C22.2#286:2023 Ed. 3]
Product:	Explosion-proof Industrial Control Panels Class I, Division 1, Group BCD T6...T1
Models:	Industrial Control Panel